

CONTRACTOR MAY PROVIDE SENSORS EQUAL TO THOSE SPECIFIED. SUBSTITUTED SENSORS MUST MATCH SPECIFIED SENSOR IN APPEARANCE, SIZE, QUALITY AND PERFORMANCE. FURNISH AND INSTALL SENSORS PER MANUFACTURERS RECOMMENDATIONS AND PROVIDE WIRING TO CONTROL RELAYS REQUIRED FOR STEP DIMMING (BI-LEVEL) SWITCHING. WALL SENSOR SWITCH SHALL BE IVORY COLOR WITH STAINLESS STEEL FACE PLATE.

■ SCALE: NONE

GENERAL NOTES:

- A. MOUNTING HEIGHTS LISTED ON PLANS ARE TO BOTTOM OF FIXTURE, UNLESS OTHERWISE NOTED. FIXTURES STEM, CABLE AND CORD LENGTHS MAY NOT BE STANDARD AND MUST BE COORDINATED WITH LIGHTING FIXTURE MANUFACTURER PRIOR TO ORDERING. COORDINATE WITH LIGHTING DRAWINGS AND ARCHITECTURAL ELEVATIONS FOR MOUNTING HEIGHTS.
- B. CONTRACTOR SHALL FURNISH (2) TWO ADDITIONAL EX1 AND EX2 TYPE EXIT SIGNS ABOVE AND BEYOND THE INDICATED CORNER OF PLUGS TO ALLOW FOR DEVIATIONS DURING CONSTRUCTION. CONTRACTOR SHALL INCLUDE LABOR FOR INSTALLATION FOR EACH OF THESE FIXTURES. IF FIXTURES ARE NOT INSTALLED, THE CONTRACTOR SHALL COORDINATE WITH THE CONSTRUCTION MANAGER FOR STORAGE OF FIXTURES BY THE OWNER.
- C. ALL EXIT SIGN AND EMERGENCY LIGHT BATTERIES SHALL BE CIRCUITED TO LOCAL UNSWITCHED LIGHTING CIRCUIT.
- D. CONTRACTOR SHALL FURNISH AND INSTALL ALL MOUNTING ACCESSORIES AND HARDWARE FOR LIGHT FIXTURES FOR AN ATTRACTIVE, CLEAN LOOKING INSTALLATION.
- E. FURNISH AND INSTALL CONTROLS AS REQUIRED FOR ALL NEW INTERIOR AND EXTERIOR BUILDING LIGHT FIXTURES AS INDICATED ON DRAWINGS. WALLPLATES FOR ALL SWITCHES, DIMMER SWITCHES, WALL OCCUPANCY SENSORS SHALL BE STAINLESS STEEL WITH WORY COLOR SWITCHES, UNLESS OTHERWISE NOTED.

CONTRACTOR MAY PROVIDE FIXTURES EQUAL TO THOSE SPECIFIED. SUBSTITUTED FIXTURES MUST MATCH SPECIFIED FIXTURE IN APPEARANCE, SIZE, QUALITY AND PERFORMANCE. ALL FIXTURES SHALL BE SUBJECT TO REVIEW BY ARCHITECT AND ENGINEER AT TIME OF LIGHTING FIXTURE SUBMITTALS. CONTRACTOR SHALL PROVIDE FIXTURES INDICATED ON SCHEDULE FOR ANY FIXTURES DEEMED NOT EQUAL BY THE ENGINEER.

